



TWO WIRE TEST STATION
(SHOWN BEHIND CURB)

(SYMBOL)

FOUR WIRE TEST STATION
(SHOWN BEHIND CURB)

(SYMBOL)

NOTES:

1. ELECTROLYSIS TEST LEADS SHALL CONFORM TO THE FOLLOWING, UNLESS OTHERWISE SPECIFIED:
 TYPE: STRANDED COPPER
 STYLE: T.H.W.N. OR U.S.E. RATED INSULATION
 MIN. SIZE: A.W.G. NO. 10
 COLOR CODE: B - BLACK
 W - WHITE
 G - GREEN
 R - RED
2. ELECTROLYSIS TEST LEADS SHALL BE ATTACHED TO THE PIPE IN ACCORDANCE WITH STANDARD DRAWING ET-1-08.
3. ET STATION VALVE BOX LOCATION IS TO BE BACK OF CURB FOR ALL INSTALLATIONS UNLESS OTHERWISE NOTED OR DIRECTED BY THE DISTRICT.
4. TEST LEAD WIRES SHALL EXTEND A MINIMUM OF 1'-0" ABOVE FINISH GRADE TO ALLOW FOR TEST CONNECTIONS. CONTRACTOR SHALL COIL EXCESS WIRE IN VALVE BOX.
5. ALL ELECTROLYSIS TEST STATIONS IN DEVELOPED AREAS SHALL HAVE CURB MARKINGS. SEE STANDARD DRAWING MP-1-08.

ALAMEDA COUNTY WATER DISTRICT
43885 SOUTH GRIMMER BOULEVARD
P.O. BOX 5110
FREMONT, CA 94537-5110
(510) 668-4200

STANDARD DRAWING

**ELECTROLYSIS TEST STATION
DEVELOPED AREAS**

APPROVED 12/15/2008
ENGINEERING MANAGER DATE

					DESIGNED	ACWD	DATE: DEC. 2008	
					DRAWN	RMF	SCALE: NONE	
0	12-08	REPLACES STD. DWG. ET-4	RMF	LJA	CHECKED	LJA	DWG. NO.	REV.
NO.	DATE	REVISION	BY	APP.	DIV. MGR.	EHS	ET-4-08	0