



NOTES:

1. TIE OFF TRACER WIRE TO SERVICE CORPORATION STOP. DO NOT CONNECT TO WATER MAIN TRACER WIRE.
2. TRACER WIRE SHALL BE INSTALLED ON ALL NON-METALLIC SERVICE LINES.
3. TRACER WIRE SHALL BE STRANDED COPPER, A.W.G. NO. 10 WITH U.S.E. RATED INSULATION, COLOR BLACK.
4. TRACER WIRE SHALL BE ATTACHED TO VERTICAL PORTION OF SERVICE LINE WITH STAINLESS STEEL STRAP OR CLAMP.



ALAMEDA COUNTY WATER DISTRICT
 43885 SOUTH GRIMMER BOULEVARD
 P.O. BOX 5110
 FREMONT, CA 94537-5110
 (510) 668-4200

STANDARD DRAWING

TRACER WIRE
 FOR SERVICE LINES

APPROVED *Albert Chavez* 12/15/2008
 ENGINEERING MANAGER DATE

				DESIGNED	ACWD	DATE: DEC. 2008	
				DRAWN	RMF	SCALE: NONE	
0	12-08	REPLACES STD. DWG. TW-2	RMF	LJA	CHECKED	LJA	DWG. NO.
NO.	DATE	REVISION	BY	APP.	DIV. MGR.	EHS	TW-2-08
							REV. 0