



- NOTES:
1. MINIMUM THICKNESS OF DIELECTRIC TAPE COATING SHALL BE AS STATED IN SPECIFICATIONS.
 2. EACH WRAP OF DIELECTRIC TAPE SHALL OVERLAP THE PRECEDING WRAP BY 5/8 x TAPE WIDTH.
 3. A DOUBLE WRAP OF DIELECTRIC TAPE SHALL EXTEND A MINIMUM OF 4" BEYOND THE POINT WHERE DIELECTRIC TAPE COATING IS SPECIFIED THICKNESS. TYPICAL ALL FIELD WRAPPED JOINTS.
 4. OPTIONAL INSIDE WELD FOR PIPE 36" DIAMETER AND LARGER WITH ADEQUATE VENTILATION.
 5. THICKNESS OF BUTT STRAP AND MORTAR ACCESS PLATE TO BE SAME OR THICKER THAN CYLINDER PIPE USED ON.

APPROVED *Albert Chavez* 12/15/2008
ENGINEERING MANAGER DATE

			DESIGNED	ACWD
			DRAWN	RMF
0	12-08	NEW STD. DWG.	CHECKED	LJA
NO.	DATE	REVISION	BY	APP. DIV. MGR.

ACWD
ALAMEDA COUNTY WATER DISTRICT
43885 SOUTH GRIMMER BOULEVARD
P.O. BOX 5110
FREMONT, CA 94537-5110
(510) 668-4200

STANDARD DRAWING		DATE: DEC. 2008
STEEL PIPE WELDED JOINTS		SCALE: NONE
DWG. NO.	REV.	
WSP-1-08	0	