ACWD Voluntary PFAS Monitoring

January 2025 - December 2025

The Alameda County Water District is committed to delivering safe drinking water to our customers. This commitment included a voluntary approach to monitoring drinking water for PFAS prior to being issued monitoring orders by the Division of Drinking Water. Below are the ranges of concentrations and running annual averages of results from the recent four quarters (First, Second, Third and Fourth Quarter of 2025) PFAS monitoring. For more information, please visit www.acwd.org/PFAS.

Peralta-Tyson Blending Facility

	PFOS		PFOA		PFBS		PFHpA		PFHxS		PFNA		PFDA		PFDoA		PFHxA		PFUnA		HFPO-DA		9Cl-PF3ONS		11Cl-PF3OUdS	
	Range	Average	Range	Average	Range	Average	Range	Average	Range	Average	Range	Average	Range	Average	Range	Average	Range	Average	Range	Average	Range	Average	Range	Average	Range	Average
Sample ID	**PFOS[1,2]**	**PFOS[1,2]**	**PFOA[1,2]**	**PFOA[1,2]**	**PFBS[1,2]**	**PFBS[1,2]**	**PFHpA[1,2]**	**PFHpA[1,2]**	**PFHxS[1,2]**	**PFHxS[1,2]**	**PFNA[1,2]**	**PFNA[1,2]**	**PFDA[1,2]**	**PFDA[1,2]**	**PFDoA[1,2]**	**PFDoA[1,2]**	**PFHxA[1,2]**	**PFHxA[1,2]**	**PFUnA[1,2]**	**PFUnA[1,2]**	**HFPO-DA[1,2]**	**HFPO-DA[1,2]**	**9Cl-PF3ONs[1,2]**	**9Cl-PF3ONs[1,2]**	**11Cl-PF3OUdS[1,2]**	**11Cl-PF3OUdS[1,2]**
Treated Water from Blending Facility [3]																										
S1	ND-3	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
San Francisco Water																										
SF1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Mowry Well Field - Blending Facility Source Wells																										
Mowry 1	11-12	11.8	2.2-2.5	2.4	6.3-7.2	6.8	ND	ND	6-6.5	6.2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Mowry 2	ND	ND	ND	ND	ND	ND	ND	ND	ND-2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Mowry 3	12-13	12.8	ND	ND	3.8-4.8	4.2	ND	ND	5.4-5.9	5.6	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Mowry 4	12-13	12.3	ND-2.3	ND	5.7-6.6	6.2	ND	ND	5.6-6.5	6.1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Mowry 6	8.4-11	9.8	ND	ND	3.1-4.3	3.8	ND	ND	5.3-6.2	5.7	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Mowry 7	11-13	12.3	2.2-3	2.7	6.4-7.6	6.9	ND	ND	6.2-7	6.5	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Mowry 8	11-12	11.5	ND-2.5	ND	6.3-6.8	6.6	ND	ND	6.3-6.6	6.4	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Mowry 9	10-13	11.8	ND	ND	3.6-4.6	4.1	ND	ND	5.9-6.2	6.0	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Peralta-Tyson Well Field - Blending Facility Source Wells																										
Peralta-Tyson 1	8.5-12	10.5	4.3-5.6	5.0	6.7-7.6	7.2	ND-2.2	ND	6.1-7.3	6.9	ND	ND	ND	ND	ND	ND	3.4-5.4	4.6	ND	ND	ND	ND	ND	ND	ND	ND
Peralta-Tyson 2	8.1-12	9.5	3.9-4.6	4.3	6.6-7.2	6.8	ND	ND	6-7	6.5	ND	ND	ND	ND	ND	ND	3.4-4.1	3.6	ND	ND	ND	ND	ND	ND	ND	ND
Peralta-Tyson 3	8.6-11	9.6	2.6-3.8	3.2	4.8-7.4	6.5	ND	ND	4.1-6.3	5.5	ND	ND	ND	ND	ND	ND	2-3.5	2.5	ND	ND	ND	ND	ND	ND	ND	ND
Peralta-Tyson 4	7.8-9	8.3	3.6-4.4	4.0	6.1-7.1	6.7	ND	ND	5.2-6.1	5.8	ND	ND	ND	ND	ND	ND	2.9-3.7	3.2	ND	ND	ND	ND	ND	ND	ND	ND
Peralta-Tyson 5	9.9-9.9	9.9	3.1-3.1	3.1	6.9-6.9	6.9	ND	ND	5.5-5.5	5.5	ND	ND	ND	ND	ND	ND	2.7-2.7	2.7	ND	ND	ND	ND	ND	ND	ND	ND
Peralta-Tyson 6	9.4-9.4	9.4	2-2	2.0	6.4-6.4	6.4	ND	ND	5.4-5.4	5.4	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Peralta-Tyson 7	8-10	9.3	ND-3.9	ND	4.8-5.8	5.4	ND	ND	3.8-5	4.4	ND	ND	ND	ND	ND	ND	ND-3	ND	ND	ND	ND	ND	ND	ND	ND	ND
Peralta-Tyson 8	8.7-10	9.7	ND	ND	5.3-6.3	5.8	ND	ND	4.9-5.9	5.4	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND

	ADONA		4:2FTS		6:2FTS		8:2FTS		NFDHA		PFBA		PFEEPFEESA		PFHpS		PFMBA		PFMPA		PFPeA		PFPeS	
	Range	Average	Range	Average	Range	Average	Range	Average	Range	Average	Range	Average	Range	Average	Range	Average	Range	Average	Range	Average	Range	Average	Range	Average
Sample ID	**ADONA[1,2]**	**ADONA[1,2]**	**4:2FTS[1,2,7]**	**4:2FTS[1,2,7]**	**6:2FTS [1,2]**	**6:2FTS [1,2]**	**8:2FTS [1,2]**	**8:2FTS [1,2]**	**NFDHA[1,2]**	**NFDHA[1,2]**	**PFBA[1,2]**	**PFBA[1,2]**	**PFEEPFEESA[1,2]**	**PFEEPFEESA[1,2]**	**PFHpS[1,2]**	**PFHpS[1,2]**	**PFMBA[1,2]**	**PFMBA[1,2]**	**PFMPA[1,2]**	**PFMPA[1,2]**	**PFPeA[1,2]**	**PFPeA[1,2]**	**PFPeS[1,2]**	**PFPeS[1,2]**
Treated Water from Blending Facility [3]																								
S1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND-2.5	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
San Francisco Water																								
SF1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND-2.2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Mowry Well Field - Blending Facility Source Wells																								
Mowry 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	3.9-4.2	4.0	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Mowry 2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Mowry 3	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND-2.3	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Mowry 4	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	3.3-4.7	4.1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Mowry 6	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND-2.1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Mowry 7	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	4.4-5.4	5.0	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Mowry 8	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	3.5-4.4	3.8	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Mowry 9	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND-2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Peralta-Tyson Well Field - Blending Facility Source Wells																								
Peralta-Tyson 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	4.9-6.4	5.5	ND	ND	ND	ND	ND	ND	ND	ND	4.2-5.2	4.9	ND	ND
Peralta-Tyson 2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	4.6-5.9	5.3	ND	ND	ND	ND	ND	ND	ND	ND	3.5-4.5	4.0	ND	ND
Peralta-Tyson 3	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	4.2-7.1	5.7	ND	ND	ND	ND	ND	ND	ND	ND	2.1-3.7	2.8	ND	ND
Peralta-Tyson 4	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	5.5-6	5.8	ND	ND	ND	ND	ND	ND	ND	ND	3.2-4.1	3.4	ND	ND
Peralta-Tyson 5	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	6.4-6.4	6.4	ND	ND	ND	ND	ND	ND	ND	ND	2.6-2.6	2.6	ND	ND
Peralta-Tyson 6	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	5.2-5.2	5.2	ND	ND	ND	ND	ND	ND	ND	ND	2-2	2.0	ND	ND
Peralta-Tyson 7	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND-7.4	4.1	ND	ND	ND	ND	ND	ND	ND	ND	ND-3.1	ND	ND	ND
Peralta-Tyson 8	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND

Newark Desalination Facility

	PFOS		PFOA		PFBS		PFHpA		PFHxS		PFNA		PFDA		PFDoA		PFHxA		PFUnA		HFPO-DA		9Cl-PF3ONS		11Cl-PF3OUdS	
	Range	Average	Range	Average	Range	Average	Range	Average	Range	Average	Range	Average	Range	Average	Range	Average	Range	Average	Range	Average	Range	Average	Range	Average	Range	Average
Sample ID	**PFOS[1,2]**	**PFOS[1,2]**	**PFOA[1,2]**	**PFOA[1,2]**	**PFBS[1,2]**	**PFBS[1,2]**	**PFHpA[1,2]**	**PFHpA[1,2]**	**PFHxS[1,2]**	**PFHxS[1,2]**	**PFNA[1,2]**	**PFNA[1,2]**	**PFDA[1,2]**	**PFDA[1,2]**	**PFDoA[1,2]**	**PFDoA[1,2]**	**PFHxA[1,2]**	**PFHxA[1,2]**	**PFUnA[1,2]**	**PFUnA[1,2]**	**HFPO-DA[1,2]**	**HFPO-DA[1,2]**	**9Cl-PF3ONs[1,2]**	**9Cl-PF3ONs[1,2]**	**11Cl-PF3OUdS[1,2]**	**11Cl-PF3OUdS[1,2]**
Treated Water from Newark Desalination Facility																										
BPW[4]	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Newark Desalination Facility Source Wells																										
Bellflower	5.8-6.8	6.2	ND	ND	ND	ND	ND	ND	3.3-3.5	3.4	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Farwell	3.3-3.8	3.6	2-2.1	2.1	3.4-3.7	3.6	ND	ND	4.2-4.8	4.6	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Cedar 1	8.4-9.6	9.0	ND	ND	ND-2.3	ND	ND	ND	3.6-3.9	3.8	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Cedar 2	8.2-9.4	8.8	3.5-4	3.7	7.3-7.8	7.6	ND	ND	11-13	12.0	ND	ND	ND	ND	ND	ND	4.5-5.2	4.8	ND	ND	ND	ND	ND	ND	ND	ND
Darvon 1	5.1-5.9	5.6	4.4-4.6	4.6	7-7.8	7.4	ND	ND	7.4-8	7.7	ND	ND	ND	ND	ND	ND	ND-2.1	ND	ND	ND	ND	ND	ND	ND	ND	ND
Darvon 2	7.7-9	8.2	ND	ND	2.3-2.5	2.4	ND	ND	3.2-3.7	3.5	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND

	ADONA		4:2FTS		6:2FTS		8:2FTS		NFDHA		PFBA		PFEEPFEESA		PFHpS		PFMBA		PFMPA		PFPeA		PFPeS	
	Range	Average	Range	Average	Range	Average	Range	Average	Range	Average	Range	Average	Range	Average	Range	Average	Range	Average	Range	Average	Range	Average	Range	Average
Sample ID	**ADONA[1,2]**	**ADONA[1,2]**	**4:2FTS[1,2,7]**	**4:2FTS[1,2,7]**	**6:2FTS [1,2,7]**	**6:2FTS [1,2,7]**	**8:2FTS [1,2]**	**8:2FTS [1,2]**	**NFDHA[1,2]**	**NFDHA[1,2]**	**PFBA[1,2]**	**PFBA[1,2]**	**PFEEPFEESA[1,2]**	**PFEEPFEESA[1,2]**	**PFHpS[1,2]**	**PFHpS[1,2]**	**PFMBA[1,2]**	**PFMBA[1,2]**	**PFMPA[1,2]**	**PFMPA[1,2]**	**PFPeA[1,2]**	**PFPeA[1,2]**	**PFPeS[1,2]**	**PFPeS[1,2]**
Treated Water from Blending Facility [3]																								
S1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND-2.5	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
San Francisco Water																								
SF1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND-2.2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Mowry Well Field - Blending Facility Source Wells																								
Mowry 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	3.9-4.2	4.0	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Mowry 2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Mowry 3	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND-2.3	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Mowry 4	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	3.3-4.7	4.1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Mowry 6	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND-2.1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Mowry 7	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	4.4-5.4	5.0	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Mowry 8	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	3.5-4.4	3.8	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Mowry 9	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND-2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Peralta-Tyson Well Field - Blending Facility Source Wells																								
Peralta-Tyson 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	4.9-6.4	5.5	ND	ND	ND	ND	ND	ND	ND	ND	4.2-5.2	4.9	ND	ND
Peralta-Tyson 2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	4.6-5.9	5.3	ND	ND	ND	ND	ND	ND	ND	ND	3.5-4.5	4.0	ND	ND
Peralta-Tyson 3	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	4.2-7.1	5.7	ND	ND	ND	ND	ND	ND	ND	ND	2.1-3.7	2.8	ND	ND
Peralta-Tyson 4	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	5.5-6	5.8	ND	ND	ND	ND	ND	ND	ND	ND	3.2-4.1	3.4	ND	ND
Peralta-Tyson 5	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	6.4-6.4	6.4	ND	ND	ND	ND	ND	ND	ND	ND	2.6-2.6	2.6	ND	ND
Peralta-Tyson 6	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	5.2-5.2	5.2	ND	ND	ND	ND	ND	ND	ND	ND	2-2	2.0	ND	ND
Peralta-Tyson 7	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND-7.4	4.1	ND	ND	ND	ND	ND	ND	ND	ND	ND-3.1	ND	ND	ND
Peralta-Tyson 8	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND

Treatment Plant 2

	PFOS		PFOA		PFBS		PFHpA		PFHxS		PFNA		PFDA		PFDoA		PFHxA		PFUnA		HFPO-DA		9Cl-PF3ONS		11Cl-PF3OUdS	
	Range	Average	Range	Average	Range	Average	Range	Average	Range	Average	Range	Average	Range	Average	Range	Average	Range	Average	Range	Average	Range	Average	Range	Average	Range	Average
Sample ID	**PFOS[1,2]**	**PFOS[1,2]**	**PFOA[1,2]**	**PFOA[1,2]**	**PFBS[1,2]**	**PFBS[1,2]**	**PFHpA[1,2]**	**PFHpA[1,2]**	**PFHxS[1,2]**	**PFHxS[1,2]**	**PFNA[1,2]**	**PFNA[1,2]**	**PFDA[1,2]**	**PFDA[1,2]**	**PFDoA[1,2]**	**PFDoA[1,2]**	**PFHxA[1,2]**	**PFHxA[1,2]**	**PFUnA[1,2]**	**PFUnA[1,2]**	**HFPO-DA[1,2]**	**HFPO-DA[1,2]**	**9Cl-PF3ONs[1,2]**	**9Cl-PF3ONs[1,2]**	**11Cl-PF3OUdS[1,2]**	**11Cl-PF3OUdS[1,2]**
Treated Water from Treatment Plant 2																										
FW2[5]	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Treatment Plant 2 Source Water																										
RW2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND

	ADONA		4:2FTS		6:2FTS		8:2FTS		NFDHA		PFBA		PFEEPFEESA		PFHpS		PFMBA		PFMPA		PFPeA		PFPeS	
	Range	Average	Range	Average	Range	Average	Range	Average	Range	Average	Range	Average	Range	Average	Range	Average	Range	Average	Range	Average	Range	Average	Range	Average
Sample ID	**ADONA[1,2]**	**ADONA[1,2]**	**4:2FTS[1,2,7]**	**4:2FTS[1,2,7]**	**6:2FTS [1,2,7]**	**6:2FTS [1,2,7]**	**8:2FTS [1,2]**	**8:2FTS [1,2]**	**NFDHA[1,2]**	**NFDHA[1,2]**	**PFBA[1,2]**	**PFBA[1,2]**	**PFEEPFEESA[1,2]**	**PFEEPFEESA[1,2]**	**PFHpS[1,2]**	**PFHpS[1,2]**	**PFMBA[1,2]**	**PFMBA[1,2]**	**PFMPA[1,2]**	**PFMPA[1,2]**	**PFPeA[1,2]**	**PFPeA[1,2]**	**PFPeS[1,2]**	**PFPeS[1,2]**
Treated Water from Blending Facility [3]																								
S1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND-2.5	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
San Francisco Water																								
SF1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND-2.2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Mowry Well Field - Blending Facility Source Wells																								
Mowry 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	3.9-4.2	4.0	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Mowry 2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Mowry 3	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND-2.3	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Mowry 4	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	3.3-4.7	4.1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Mowry 6	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND-2.1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Mowry 7	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	4.4-5.4	5.0	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Mowry 8	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	3.5-4.4	3.8	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Mowry 9	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND-2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Peralta-Tyson Well Field - Blending Facility Source Wells																								
Peralta-Tyson 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	4.9-6.4	5.5	ND	ND	ND	ND	ND	ND	ND	ND	4.2-5.2	4.9	ND	ND
Peralta-Tyson 2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	4.6-5.9	5.3	ND	ND	ND	ND	ND	ND	ND	ND	3.5-4.5	4.0	ND	ND
Peralta-Tyson 3	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	4.2-7.1	5.7	ND	ND	ND	ND	ND	ND	ND	ND	2.1-3.7	2.8	ND	ND
Peralta-Tyson 4	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	5.5-6	5.8	ND	ND	ND	ND	ND	ND	ND	ND	3.2-4.1	3.4	ND	ND
Peralta-Tyson 5	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	6.4-6.4	6.4	ND	ND	ND	ND	ND	ND	ND	ND	2.6-2.6	2.6	ND	ND
Peralta-Tyson 6	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	5.2-5.2	5.2	ND	ND	ND	ND	ND	ND	ND	ND	2-2	2.0	ND	ND
Peralta-Tyson 7	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND-7.4	4.1	ND	ND	ND	ND	ND	ND	ND	ND	ND-3.1	ND	ND	ND
Peralta-Tyson 8	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND

Notes:

(1) ppt - parts per trillion (all results are in ppt)

(2) ND - Not Detected (at the Method Detection Limit of 2 ppt)

(3) S1 - Treated Water from the Blending Facility is a blend of San Francisco Water and well water from the Mowry or Peralta-Tyson wellfields and denoted by sample ID "S1"

(4) BPW - Blended Product Water

(5) FW2 - Treated Water from Water Treatment Plant 2.